



Specifications

A515A Series

Quiet Bathroom Exhaust Fan

Description: Low noise, low RPM, ceiling mount bathroom exhaust fan and heater • Suitable for new construction, or remodeling • Conforms to UL/CUL safety standards when used with GFCI circuit wiring • Includes 2 anti-blast infrared heat lamps and a 60W incandescent bulb • 3-function wall switch included.

Motor/Blower: Permanently lubricated enclosed condenser motor engineered for quiet exhaust operation; power rating 120v/60Hz; motor equipped with thermal shut off.

Housing: Rust proof paint on steel body; 4" duct connector with built-in back draft dampener; easy installation anti-vibration brackets included; designed for installation in ceilings with minimum of 8" clearance.

Grille: Low maintenance, wipe clean; attaches to housing with torsion springs

Finishes: White (W), Silver (S), Oil Rubbed Bronze (OR)


Ventilating Area: For bathrooms up to 80 sq ft.

Installation: Must be installed by a licensed professional. Requires a dedicated 10-amp circuit. Complete installation instructions included.

Shipping Weight: 14 lbs

Warranty: 4 Years

Architect's Specifications: Exhaust fan will be ceiling mount with no less than 80 CFM and no more than 1.0 Sones at 0.1 static pressure in inches water gauge. Power consumption shall be no greater than 610 watts. The motor will be permanently lubricated, engineered for quiet operation with thermal shut off. Duct diameter will be 4" round. Exhaust fan, heater, and light may be wired separately. Exhaust fan will not be installed directly over tub/shower enclosure. Exhaust fan shall be UL/CUL listed for use in insulated ceiling (Type I.C.).



Listed for use in insulated ceilings (Type I.C.) Do not install directly over tub/shower.



A (OR) • A (S) • A (W)



Model: A515A Series	4" Duct
Static Pressure (inches w.g.)	0.1
Air Volume (CFM)	80
Noise (sones)	1.0
Power Consumption (Watts)	610
Current (AMPS)	5.1
Housing Dimensions (ins)	7 1/4 x 7 1/8 x 13 3/16
Grille Dimensions (ins)	9 1/16 x 15 3/4

Model	Qty	Comments	Project
			Location
			Architect
			Engineer
			Contractor
			Submitted by
			Date